



Product Service

# CERTIFICATE


No. Z2 18 02 84700 060

**Holder of Certificate:** **Phono Solar Technology Co., Ltd**

No. 1 Xinghuo Rd.,  
Nanjing Hi-tech Zone,  
210032 Nanjing  
PEOPLE'S REPUBLIC OF CHINA



**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704061800303-00

**Valid until:** 2023-02-01



**Date,** 2018-02-08 (Zhulin Zhang)

Page 1 of 2



Product Service

## CERTIFICATE

No. Z2 18 02 84700 060

### Model(s):

**1500 V DC system voltage modules:**  
PS350MH-24/T, PS355MH-24/T, PS360MH-24/T  
PS290MH-20/U, PS295MH-20/U, PS300MH-20/U  
**1000 V DC system voltage modules:**  
PS350M-24/T, PS355M-24/T, PS360M-24/T  
PS290M-20/U, PS295M-20/U, PS300M-20/U

### Parameters:

Rated Output Power at STC: 1500 V DC system modules:  
350 W, 355 W, 360 W  
290 W, 295 W, 300 W  
1000 V DC system modules:  
350 W, 355 W, 360 W  
290 W, 295 W, 300 W

Construction: Framed, with Junction box,  
Cable and Connectors.

Safety Class: Class II

Maximum System Voltage: 1500 V DC or 1000 V DC

Fire Safety Class: Class C

PID test condition: -1500 V DC or -1000 V DC,  
96 Hours, 85 °C , 85 % RH

PID testing method is according to IEC TS 62804-1:2015

### Tested according to:

IEC 61215-1(ed.1)  
IEC 61215-1-1(ed.1)  
IEC 61215-2(ed.1)  
IEC 61730-1(ed.2)  
IEC 61730-2(ed.2)  
PPP 58042B:2015

### Production Facility(ies):

84700, 98336